
STATUTORY INSTRUMENTS

2016 No. 614

The Water Supply (Water Quality) Regulations 2016

PART 5

Monitoring – additional provisions

Sampling at service reservoirs

14. Every water undertaker or [^{F1}wholesale licensee] must take or cause to be taken, from each of its service reservoirs in each week in which the reservoir is in use [^{F2}or as specified in a notice given by the Secretary of State under regulation 9(3)], one sample for analysis—

- (a) for testing for compliance with the prescribed concentrations or values in respect of the coliform bacteria and *E. coli* parameters,
- (b) for determining the concentration of the residual disinfectant, and
- (c) for determining whether the specification in relation to the colony counts parameter is met.

F1 Words in regs. 14-18 substituted (31.3.2017) by [The Water Act 2014 \(Consequential Amendments etc.\) Order 2017 \(S.I. 2017/506\)](#), arts. 1(1), **32(4)**

F2 Words in [reg. 14](#) inserted (11.7.2018) by [The Water Supply \(Water Quality\) \(Amendment\) Regulations 2018 \(S.I. 2018/706\)](#), regs. 1(1), **2(10)**

Changes to legislation:

There are currently no known outstanding effects for the The Water Supply (Water Quality) Regulations 2016, Section 14.