
STATUTORY INSTRUMENTS

2016 No. 614

The Water Supply (Water Quality) Regulations 2016

PART 5

Monitoring – additional provisions

Sampling at service reservoirs

14. Every water undertaker or combined licensee must take or cause to be taken, from each of its service reservoirs in each week in which the reservoir is in use, one sample for analysis—

- (a) for testing for compliance with the prescribed concentrations or values in respect of the coliform bacteria and *E. coli* parameters,
- (b) for determining the concentration of the residual disinfectant, and
- (c) for determining whether the specification in relation to the colony counts parameter is met.