

SCHEDULE 1

Prescribed concentrations or values

PART 2

Indicator parameters (excluding radioactive substances)

Table C

Prescribed concentrations, values or states

<i>Parameters</i>	<i>Maximum concentration or value or state (unless otherwise stated)</i>	<i>Units of measurement</i>
Ammonium	0.50	mg/l
Chloride ⁽ⁱ⁾	250	mg/l
<i>Clostridium perfringens</i> (including spores)	0	Number/100ml
Coliform bacteria	0	Number/100ml (Number/250 ml in the case of water put into bottles of containers)
Colony counts	No abnormal change	Number/ml at 22°
Conductivity ⁽ⁱ⁾	2500	Number/ml at 37°C
Conductivity ⁽ⁱ⁾	2500	µS/cm at 20°C
Hydrogen ion	9.5 (maximum) 6.5 (minimum) (in the case of still water put into bottles or containers the minimum is 4.5)	pH value pH value
Sulphate ⁽ⁱ⁾	250	mg/l
Total organic carbon (TOC)	No abnormal change	mgC/l
Turbidity ⁽ⁱⁱ⁾	1	NTU

(i) The water should not be aggressive.

(ii) Only in the case of surface water or groundwater that has been influenced by surface water.