

---

STATUTORY INSTRUMENTS

---

**2018 No. 1206**

**The Guarantees of Origin of Electricity  
Produced from High-efficiency Cogeneration  
(Amendment) (EU Exit) Regulations 2018**

**PART 3**

Amendment of subordinate legislation: European Union (Withdrawal) Act 2018

**Amendment of the Guarantees of Origin of Electricity Produced from High-efficiency  
Cogeneration Regulations 2007**

**3.—(1)** The Guarantees of Origin of Electricity Produced from High-efficiency Cogeneration Regulations 2007(1) are amended as follows.

(2) For regulation 2, substitute—

**“Interpretation**

**2.** In these Regulations—

“CHPGO” means a guarantee of origin of electricity produced from high-efficiency cogeneration(2);

“the CHPGO holder” means the person to whom the CHPGO is issued or transferred;

“cogeneration” means the simultaneous generation in one process of thermal energy and electrical or mechanical energy;

“cogeneration unit” means a unit that is able to operate in cogeneration mode;

“the competent authority” is the Secretary of State for Business, Energy and Industrial Strategy;

“economically justifiable demand” means demand that does not exceed the needs for heating or cooling and which would otherwise be satisfied at market conditions by energy generation processes other than cogeneration;

“electricity from cogeneration” means electricity generated in a process linked to the production of useful heat and calculated in accordance with the methodology laid down in Schedule 4;

“energy” means all forms of energy products, combustible fuels, heat, renewable energy, electricity, or any other form of energy;

“Energy Efficiency Directive” means [Directive 2012/27/EU](#) of the European Parliament and of the Council of 25th October 2012 on energy efficiency, amending Directives

---

(1) [S.I. 2007/292](#), as amended by [S.I. 2009/229](#), [2014/1403](#), [2016/992](#) and [2016/1108](#).

(2) Cogeneration is commonly referred to in the United Kingdom as combined heat and power or CHP.

2009/125/EC and 2010/30/EU and repealing Directives 2004/8/EC and 2006/32/EC(3), as it applies in the European Union;

“Great Britain” includes—

- (a) the territorial sea of the United Kingdom which is adjacent to Great Britain; and
- (b) any area designated under the Continental Shelf Act 1964(4);

“guarantee of origin” means, except in relation to paragraphs (3) to (5) of regulation 10, a certificate issued by the competent authority certifying that the electricity in respect of which the certificate is issued is electricity produced from high-efficiency cogeneration;

“harmonised efficiency reference values” means the values indicated in paragraph 7 of Schedule 7 and set in accordance with that paragraph and with Commission Delegated Regulation (EU) 2015/2402 of 12 October 2015 reviewing harmonised efficiency reference values for separate production of electricity and heat in application of Directive 2012/27/EU of the European Parliament and of the Council;

“high-efficiency cogeneration” means cogeneration that meets the criteria in Schedule 3;

“micro-cogeneration unit” means a cogeneration unit with a maximum capacity below 50 kilowatt electrical (kW<sub>e</sub>);

“overall efficiency” means the annual sum of electricity and mechanical energy production and useful heat output divided by the fuel input used for heat produced in a cogeneration process and gross electricity and mechanical energy production;

“power-to-heat ratio” means the ratio of electricity from cogeneration to useful heat when operating in full cogeneration mode using operational data of the specific unit;

“small-scale cogeneration unit” means a cogeneration unit with installed capacity below 1 megawatt electrical (MW<sub>e</sub>);

“useful heat” means heat produced in a cogeneration process to satisfy economically justifiable demand for heating or cooling.”.

(3) In regulation 3—

- (a) in the heading, omit “and designation of the competent authority”;
- (b) omit paragraph (2).

(4) In regulation 5(3)(a), for “information required by paragraph (b) of Annex X to the Energy Efficiency Directive”, substitute “matters set out in Schedule 2”.

(5) In regulation 10—

- (a) in paragraph (1), for “Annex X to the Energy Efficiency Directive”, substitute “Schedule 2”;
- (b) for paragraph (3), substitute—

“(3) Subject to paragraph (4), a public authority must recognise, as proof of the matters referred to in Schedule 2, a CHPGO which has been issued—

- (a) in a member State in accordance with article 14(10) of the Energy Efficiency Directive; or
- (b) in Northern Ireland in accordance with the Guarantees of Origin of Electricity Produced from High-efficiency Cogeneration Regulations (Northern Ireland) 2008(5).”;

(c) in paragraph (5)—

(3) OJ L 315 14.11.2012, p. 1, as last amended by Directive (EU) 2018/844 (OJ L 156, 19.6.2018, p. 75).

(4) 1964 c.29, as amended by the Oil and Gas (Enterprise) Act 1982 (c.23) and the Energy Act 2011 (c.16).

(5) S.R. 2008 No. 287, as amended by S.R. 2014 No. 284.

- (i) for “another”, substitute “a”;
  - (ii) for “requires”, substitute “required before exit day”.
- (6) After Schedule 1, insert—

“SCHEDULE 2

Regulations 5(3) and 10(1) and (3)

Information to be contained in a CHPGO

1. The identity, location, type and capacity (thermal and electrical) of the installation where the energy was produced.
2. The dates and places of production.
3. The lower calorific value of the fuel source from which the electricity was produced.
4. The quantity and the use of the heat generated together with the electricity.
5. The quantity of electricity from high-efficiency cogeneration calculated in accordance with Schedule 3 that the guarantee of origin represents.
6. The primary energy savings calculated in accordance with Schedule 3 based on the harmonised efficiency reference values.
7. The nominal electric and thermal efficiency of the plant.
8. Whether and to what extent the installation has benefited from investment support.
9. Whether and to what extent the unit of energy has benefited in any other way from a national support scheme, and the type of support scheme.
10. The date on which the installation became operational.
11. The date and country of issue and a unique identification number.

SCHEDULE 3

Regulation 2 and paragraphs 5 and 6 of  
Schedule 2

Methodology for determining the efficiency of the cogeneration process

**Values to be used**

1. Values used for calculation of efficiency of cogeneration and primary energy savings must be determined on the basis of the expected or actual operation of the unit under normal conditions of use.

**High-efficiency cogeneration**

2. For the purposes of these Regulations high-efficiency cogeneration shall fulfil the following criteria—
  - (a) cogeneration production from cogeneration units shall provide primary energy savings, calculated in accordance with paragraph 3, of at least 10% compared with the references for separate production of heat and electricity;
  - (b) production from small-scale and micro-cogeneration units providing primary energy savings may qualify as high-efficiency cogeneration.

**Calculation of primary energy savings**

3. The amount of primary energy savings provided by cogeneration production defined in accordance with Schedule 4 must be calculated on the basis of the following formula—

$$PES = \left( 1 - \frac{1}{\frac{CHP H\eta}{Ref H\eta} + \frac{CHP E\eta}{Ref E\eta}} \right) \times 100\%$$

where—

PES is primary energy savings;

CHP H $\eta$  is the heat efficiency of the cogeneration production defined as annual useful heat output divided by the fuel input used to produce the sum of useful heat output and electricity from cogeneration;

Ref H $\eta$  is the harmonised efficiency reference value for separate heat production;

CHP E $\eta$  is the electrical efficiency of the cogeneration production defined as annual electricity from cogeneration divided by the fuel input used to produce the sum of useful heat output and electricity from cogeneration. For the purpose only of calculating the electrical efficiency of the cogeneration production, where a cogeneration unit generates mechanical energy, the annual electricity from cogeneration may be increased by an additional element representing the amount of electricity which is equivalent to that of mechanical energy;

Ref E $\eta$  is the harmonised efficiency reference value for separate electricity production.

**Calculations of primary energy savings using alternative calculation**

4.—(1) The competent authority may calculate primary energy savings from a production of heat and electricity and mechanical energy in accordance with sub-paragraph (2) without applying Schedule 4 to exclude the non-cogenerated heat and electricity parts of the same process. Such a production can be regarded as high-efficiency cogeneration provided it fulfils the efficiency criteria in paragraph 2 and, for cogeneration units with an electrical capacity larger than 25 megawatts (MW), the overall efficiency is above 70%. However, specification of the quantity of electricity from cogeneration produced in such a production, for issuing a guarantee of origin, must be determined in accordance with Schedule 4.

(2) If primary energy savings for a process are calculated using the alternative calculation in accordance with sub-paragraph (1), the primary energy savings must be calculated using the formula in paragraph 3 but replacing “CHP H $\eta$ ” with “H $\eta$ ” and “CHP E $\eta$ ” with “E $\eta$ ”, where—

H $\eta$  means the heat efficiency of the process, defined as the annual heat output divided by the fuel input used to produce the sum of heat output and electricity output;

E $\eta$  means the electricity efficiency of the process, defined as the annual electricity output divided by the fuel input used to produce the sum of heat output and electricity output. For the purpose only of calculating the electrical efficiency of the cogeneration production, where a cogeneration unit generates mechanical energy, the annual electricity from cogeneration may be increased by an additional element representing the amount of electricity which is equivalent to that of mechanical energy.

5. The competent authority may use other reporting periods than one year for the purpose of the calculations according to paragraphs 3 and 4.

6. For micro-cogeneration units the calculation of primary energy savings may be based on certified data.

### **Efficiency reference values for separate production of heat and electricity**

7.—(1) The harmonised efficiency reference values consist of a matrix of values differentiated by relevant factors, including year of construction and types of fuel, and must be based on a well-documented analysis taking, inter alia, into account data from operational use under realistic conditions, fuel mix and climate conditions as well as applied cogeneration technologies.

(2) The efficiency reference values for separate production of heat and electricity in accordance with the formula set out in paragraph 3 establish the operating efficiency of the separate heat and electricity production that cogeneration is intended to substitute.

(3) The efficiency reference values must be calculated according to the following principles—

- (a) for cogeneration units the comparison with separate electricity production must be based on the principle that the same fuel categories are compared;
- (b) each cogeneration unit must be compared with the best available and economically justifiable technology for separate production of heat and electricity on the market in the year of construction of the cogeneration unit;
- (c) the efficiency reference values for cogeneration units older than 10 years of age must be fixed on the reference values of units of 10 years of age;
- (d) the efficiency reference values for separate electricity production and heat production must reflect the climate of the United Kingdom.

## SCHEDULE 4

Regulation 2 and paragraphs 3 and 4 of  
Schedule 3

### General principles for the calculation of electricity from cogeneration

#### *General principles*

1.—(1) Values used for calculation of electricity from cogeneration must be determined on the basis of the expected or actual operation of the unit under normal conditions of use. For micro-cogeneration units the calculation may be based on certified values.

(2) Electricity production from cogeneration must be considered equal to total annual electricity production of the unit measured at the outlet of the main generators—

- (a) in cogeneration units of the types referred to in paragraph 2(b) and (d) to (h) with an annual overall efficiency at a level of at least 75%; and
- (b) in cogeneration units of the types referred to in paragraph 2(a) and (c) with an annual overall efficiency at a level of at least 80%.

(3) In cogeneration units with an annual overall efficiency below the value referred to in sub-paragraph (2)(a) or with an annual overall efficiency below the value referred to in sub-paragraph (2)(b) cogeneration is calculated according to the following formula—

$$E_{CHP} = H_{CHP} \times C$$

where—

$E_{CHP}$  is the amount of electricity from cogeneration;

$C$  is the power-to-heat ratio;

$H_{\text{CHP}}$  is the amount of useful heat from cogeneration (calculated for this purpose as total heat production minus any heat produced in separate boilers or by live steam extraction from the steam generator before the turbine).

(4) For the purposes of sub-paragraph (3), the calculation of electricity from cogeneration must be based on the actual power-to-heat ratio. If the actual power-to-heat ratio of a cogeneration unit is not known, the following default values may be used for units of types (a), (b), (c), (d) and (e) referred to in paragraph 2 provided that the calculated cogeneration electricity is less or equal to total electricity production of the unit—

<i>Type of unit</i>	<i>Default power to heat ratio, C</i>
Combined cycle gas turbine with heat recovery	0.95
Steam back pressure turbine	0.45
Steam condensing extraction turbine	0.45
Gas turbine with heat recovery	0.55
Internal combustion engine	0.75

(5) If a share of the energy content of the fuel input to the cogeneration process is recovered in chemicals and recycled this share can be subtracted from the fuel input before calculating the overall efficiency used in sub-paragraphs (2) and (3).

(6) The power-to-heat ratio when operating in cogeneration mode at a capacity lower than full cogeneration is the ratio of electricity to useful heat determined using operational data of the specific unit.

(7) The Secretary of State may use other reporting periods than one year for the purpose of the calculations according to sub-paragraphs (2) and (3).

#### *Cogeneration technologies covered by these Regulations*

2. The cogeneration technologies covered by these Regulations are—

- (a) combined cycle gas turbine with heat recovery;
- (b) steam back pressure turbine;
- (c) steam condensing extraction turbine;
- (d) gas turbine with heat recovery;
- (e) internal combustion engine;
- (f) microturbines;
- (g) Stirling engines;
- (h) fuel cells;
- (i) steam engines;
- (j) Organic Rankine cycles;
- (k) any other type of technology or combination thereof involving the simultaneous generation in one process of thermal energy and electrical or mechanical energy.

3. When determining the values used for the calculation of electricity from cogeneration, the detailed Guidelines established by Commission [Decision 2008/952/EC](#) of 19 November 2008 establishing detailed guidelines for the implementation and application of Annex 2 to [Directive 2004/8/EC](#) of the European Parliament and of the Council must be applied.”.

## **Amendment of the Guarantees of Origin of Electricity Produced from High-efficiency Cogeneration Regulations (Northern Ireland) 2008**

4.—(1) The Guarantees of Origin of Electricity Produced from High-efficiency Cogeneration Regulations (Northern Ireland) 2008 are amended as follows.

(2) In regulation 2—

(a) for paragraph (1), substitute—

“(1) For the purposes of these Regulations—

“CHPGO” means a guarantee of origin of electricity produced from high-efficiency cogeneration;

“the CHPGO holder” means the person to whom the CHPGO is issued or transferred;

“CHPQA” means the Combined Heat and Power Quality Assurance programme referred to in the CHPQA Standard and accompanying CHPQA guidance notes, Issue 6, October 2016, prepared on behalf of the Department for Business, Energy and Industrial Strategy<sup>(6)</sup>;

“cogeneration” means the simultaneous generation in one process of thermal energy and electrical or mechanical energy;

“cogeneration unit” means a unit that is able to operate in cogeneration mode;

“the competent authority” means the Department for the Economy;

“economically justifiable demand” means demand that does not exceed the needs for heating or cooling and which would otherwise be satisfied at market conditions by energy generation processes other than cogeneration;

“electricity from cogeneration” means electricity generated in a process linked to the production of useful heat and calculated in accordance with the methodology laid down in Schedule 4;

“energy” means all forms of energy products, combustible fuels, heat, renewable energy, electricity, or any other form of energy;

“Energy Efficiency Directive” means [Directive 2012/27/EU](#) of the European Parliament and of the Council of 25th October 2012 on energy efficiency, amending Directives [2009/125/EC](#) and [2010/30/EU](#) and repealing Directives [2004/8/EC](#) and [2006/32/EC](#)<sup>(7)</sup>, as it applies in the European Union;

“Great Britain” includes—

(a) the territorial sea of the United Kingdom which is adjacent to Great Britain; and

(b) any area designated under the Continental Shelf Act 1964;

“guarantee of origin” means, except in relation to paragraphs (3) to (5) of regulation 10, a certificate issued by the competent authority certifying that the electricity in respect of which the certificate is issued is electricity produced from high-efficiency cogeneration;

“harmonised efficiency reference values” means the values indicated in paragraph 7 of Schedule 7 and set in accordance with that paragraph and with Commission Delegated Regulation (EU) 2015/2402 of 12 October 2015 reviewing harmonised efficiency reference values for separate production of electricity and heat in application of [Directive 2012/27/EU](#) of the European Parliament and of the Council;

---

(6) Available online at <https://www.gov.uk/combined-heat-power-quality-assurance-programme> or available from the CHPQA Administrator by telephoning 01235 753004 or emailing [chpqainfo@chpqa.com](mailto:chpqainfo@chpqa.com).

(7) OJ L 315 14.11.2012, p. 1, as last amended by Directive (EU) 2018/844 (OJ L 156, 19.6.2018, p. 75).

“high-efficiency cogeneration” means cogeneration that meets the criteria in Schedule 3;

“micro-cogeneration unit” means a cogeneration unit with a maximum capacity below 50 kilowatt electrical (kW<sub>e</sub>);

“overall efficiency” means the annual sum of electricity and mechanical energy production and useful heat output divided by the fuel input used for heat produced in a cogeneration process and gross electricity and mechanical energy production;

“power-to-heat ratio” means the ratio of electricity from cogeneration to useful heat when operating in full cogeneration mode using operational data of the specific unit;

“small-scale cogeneration unit” means a cogeneration unit with installed capacity below 1 megawatt electrical (MW<sub>e</sub>);

“useful heat” means heat produced in a cogeneration process to satisfy economically justifiable demand for heating or cooling.”;

(b) omit paragraph (2).

(3) In regulation 3, omit paragraph (2).

(4) In regulation 4(4)(b), for “in another Member State of Great Britain”<sup>(8)</sup>, substitute “to any person outside Northern Ireland”.

(5) In regulation 5(3)(a), for “information required by paragraph (b) of Annex X to the Energy Efficiency Directive”, substitute “matters set out in Schedule 2”.

(6) In regulation 10—

(a) in paragraph (1)—

(i) for “any”, substitute “the”;

(ii) for “Annex X to the Energy Efficiency Directive”, substitute “Schedule 2”;

(b) for paragraph (3), substitute—

“(3) Subject to paragraph (4), a public authority must recognise, as proof of the matters referred to in Schedule 2, a CHPGO which has been issued—

(a) in a member State in accordance with article 14(10) of the Energy Efficiency Directive; or

(b) in Great Britain in accordance with the Guarantees of Origin of Electricity Produced from High-efficiency Cogeneration Regulations 2007<sup>(9)</sup>.”;

(c) in paragraph (5)—

(i) for “another”, substitute “a”;

(ii) for “requires”, substitute “required before exit day”;

(d) in paragraph (6), for “another”, substitute “a”.

(7) After Schedule 1, insert—

## “SCHEDULE 2

Regulation 5(3) and 10(1) and (3)

### Information to be contained in a CHPGO

1. The identity, location, type and capacity (thermal and electrical) of the installation where the energy was produced.

<sup>(8)</sup> The Regulations as originally made contain a typographical error, saying “of” instead of “or”.

<sup>(9)</sup> S.I. 2007/292, as amended by S.I. 2009/229, 2014/1403 and 2016/992 and 1108.



2. The dates and places of production.
3. The lower calorific value of the fuel source from which the electricity was produced.
4. The quantity and the use of the heat generated together with the electricity.
5. The quantity of electricity from high-efficiency cogeneration calculated in accordance with Schedule 3 that the guarantee of origin represents.
6. The primary energy savings calculated in accordance with Schedule 3 based on the harmonised efficiency reference values.
7. The nominal electric and thermal efficiency of the plant.
8. Whether and to what extent the installation has benefited from investment support.
9. Whether and to what extent the unit of energy has benefited in any other way from a national support scheme, and the type of support scheme.
10. The date on which the installation became operational.
11. The date and country of issue and a unique identification number.

### SCHEDULE 3

Regulation 2 and paragraph 5 and 6 of  
Schedule 2

#### Methodology for determining the efficiency of the cogeneration process

##### Values to be used

1. Values used for calculation of efficiency of cogeneration and primary energy savings must be determined on the basis of the expected or actual operation of the unit under normal conditions of use.

##### High-efficiency cogeneration

2. For the purposes of these Regulations high-efficiency cogeneration shall fulfil the following criteria—
  - (a) cogeneration production from cogeneration units shall provide primary energy savings, calculated in accordance with paragraph 3, of at least 10% compared with the references for separate production of heat and electricity;
  - (b) production from small-scale and micro-cogeneration units providing primary energy savings may qualify as high-efficiency cogeneration.

##### Calculation of primary energy savings

3. The amount of primary energy savings provided by cogeneration production defined in accordance with Schedule 4 must be calculated on the basis of the following formula—

$$PES = \left( 1 - \frac{1}{\frac{CHP H\eta}{Ref H\eta} + \frac{CHP E\eta}{Ref E\eta}} \right) \times 100\%$$

where—

PES is primary energy savings;

CHP  $H_{\eta}$  is the heat efficiency of the cogeneration production defined as annual useful heat output divided by the fuel input used to produce the sum of useful heat output and electricity from cogeneration;

Ref  $H_{\eta}$  is the harmonised efficiency reference value for separate heat production;

CHP  $E_{\eta}$  is the electrical efficiency of the cogeneration production defined as annual electricity from cogeneration divided by the fuel input used to produce the sum of useful heat output and electricity from cogeneration. For the purpose only of calculating the electrical efficiency of the cogeneration production, where a cogeneration unit generates mechanical energy, the annual electricity from cogeneration may be increased by an additional element representing the amount of electricity which is equivalent to that of mechanical energy;

Ref  $E_{\eta}$  is the harmonised efficiency reference value for separate electricity production.

### **Calculations of primary energy savings using alternative calculation**

4.—(1) The competent authority may calculate primary energy savings from a production of heat and electricity and mechanical energy in accordance with sub-paragraph (2) without applying Schedule 4 to exclude the non-cogenerated heat and electricity parts of the same process. Such a production can be regarded as high-efficiency cogeneration provided it fulfils the efficiency criteria in paragraph 2 and, for cogeneration units with an electrical capacity larger than 25 megawatts (MW), the overall efficiency is above 70%. However, specification of the quantity of electricity from cogeneration produced in such a production, for issuing a guarantee of origin, must be determined in accordance with Schedule 4.

(2) If primary energy savings for a process are calculated using the alternative calculation in sub-paragraph (1) the primary energy savings must be calculated using the formula in paragraph 3 but replacing “CHP  $H_{\eta}$ ” with “ $H_{\eta}$ ” and “CHP  $E_{\eta}$ ” with “ $E_{\eta}$ ”, where—

$H_{\eta}$  means the heat efficiency of the process, defined as the annual heat output divided by the fuel input used to produce the sum of heat output and electricity output;

$E_{\eta}$  means the electricity efficiency of the process, defined as the annual electricity output divided by the fuel input used to produce the sum of heat output and electricity output. For the purpose only of calculating the electrical efficiency of the cogeneration production, where a cogeneration unit generates mechanical energy, the annual electricity from cogeneration may be increased by an additional element representing the amount of electricity which is equivalent to that of mechanical energy.

5. The competent authority may use other reporting periods than one year for the purpose of the calculations according to paragraphs 3 and 4.

6. For micro-cogeneration units the calculation of primary energy savings may be based on certified data.

### **Efficiency reference values for separate production of heat and electricity**

7.—(1) The harmonised efficiency reference values consist of a matrix of values differentiated by relevant factors, including year of construction and types of fuel, and must be based on a well-documented analysis taking, inter alia, into account data from operational use under realistic conditions, fuel mix and climate conditions as well as applied cogeneration technologies.

(2) The efficiency reference values for separate production of heat and electricity in accordance with the formula set out in paragraph 3 establish the operating efficiency of the separate heat and electricity production that cogeneration is intended to substitute.

(3) The efficiency reference values must be calculated according to the following principles—

- (a) for cogeneration units the comparison with separate electricity production must be based on the principle that the same fuel categories are compared;
- (b) each cogeneration unit must be compared with the best available and economically justifiable technology for separate production of heat and electricity on the market in the year of construction of the cogeneration unit;
- (c) the efficiency reference values for cogeneration units older than 10 years of age must be fixed on the reference values of units of 10 years of age;
- (d) the efficiency reference values for separate electricity production and heat production must reflect the climate of the United Kingdom.

## SCHEDULE 4

Regulation 2 and paragraphs 3 and 4 of  
Schedule 3

## General principles for the calculation of electricity from cogeneration

*General principles*

1.—(1) Values used for calculation of electricity from cogeneration must be determined on the basis of the expected or actual operation of the unit under normal conditions of use. For micro-cogeneration units the calculation may be based on certified values.

(2) Electricity production from cogeneration must be considered equal to total annual electricity production of the unit measured at the outlet of the main generators—

- (a) in cogeneration units of the types referred to in paragraph 2(b) and (d) to (h) with an annual overall efficiency at a level of at least 75%; and
- (b) in cogeneration units of the types referred to in paragraph 2(a) and (c) with an annual overall efficiency at a level of at least 80%.

(3) In cogeneration units with an annual overall efficiency below the value referred to in sub-paragraph (2)(a) or with an annual overall efficiency below the value referred to in sub-paragraph (2)(b) cogeneration is calculated according to the following formula—

$$E_{CHP} = H_{CHP} \times C$$

where—

$E_{CHP}$  is the amount of electricity from cogeneration;

$C$  is the power-to-heat ratio;

$H_{CHP}$  is the amount of useful heat from cogeneration (calculated for this purpose as total heat production minus any heat produced in separate boilers or by live steam extraction from the steam generator before the turbine).

(4) For the purposes of sub-paragraph (3), the calculation of electricity from cogeneration must be based on the actual power-to-heat ratio. If the actual power-to-heat ratio of a cogeneration unit is not known, the following default values may be used for units of types (a), (b), (c), (d) and (e) referred to in paragraph 2 provided that the calculated cogeneration electricity is less or equal to total electricity production of the unit—

<i>Type of unit</i>	<i>Default power to heat ratio, C</i>
Combined cycle gas turbine with heat recovery	0.95

<i>Type of unit</i>	<i>Default power to heat ratio, C</i>
Steam back pressure turbine	0.45
Steam condensing extraction turbine	0.45
Gas turbine with heat recovery	0.55
Internal combustion engine	0.75

(5) If a share of the energy content of the fuel input to the cogeneration process is recovered in chemicals and recycled this share can be subtracted from the fuel input before calculating the overall efficiency used in sub-paragraphs (2) and (3).

(6) The power-to-heat ratio when operating in cogeneration mode at a capacity lower than full cogeneration is the ratio of electricity to useful heat determined using operational data of the specific unit.

(7) The competent authority may use other reporting periods than one year for the purpose of the calculations according to sub-paragraphs (2) and (3).

#### *Cogeneration technologies covered by these Regulations*

2. The cogeneration technologies covered by these Regulations are—

- (a) combined cycle gas turbine with heat recovery;
- (b) steam back pressure turbine;
- (c) steam condensing extraction turbine;
- (d) gas turbine with heat recovery;
- (e) internal combustion engine;
- (f) microturbines;
- (g) Stirling engines;
- (h) fuel cells;
- (i) steam engines;
- (j) Organic Rankine cycles;
- (k) any other type of technology or combination thereof involving the simultaneous generation in one process of thermal energy and electrical or mechanical energy.

3. When determining the values used for the calculation of electricity from cogeneration, the detailed Guidelines established by Commission [Decision 2008/952/EC](#) of 19 November 2008 establishing detailed guidelines for the implementation and application of Annex 2 to [Directive 2004/8/EC](#) of the European Parliament and of the Council must be applied.”.